



COMPLAINT, INCIDENT, AND NOTIFICATION REPORT FORM

Type (Circle One): C I N

CASE NUMBER: 19052801 —

Received Date: 05/28/19 Received Time: 12:17PM Received By: JP Lead: JP

Incident Date: 05/28/19 Incident Time: 11:53AM Assigned to: Assigned Date:

COMPLAINANT / REPORTING PARTY:

Name: CONFIRE DISPATCH CENTER RP is from Facility Anonymous

Organization:

Primary Phone Number: 925-222-1392 Secondary Phone Number:

Email:

Address:

City: State: Zip Code:

FACILITY / LOCATION OF INCIDENT:

Name: CUPA Facility I.D.:

Phone Number:

Address: 759 PINE AVENUE Unit:

City: PINOLE State: CA Zip Code: 94564

Location Description:

INITIAL INCIDENT DESCRIPTION:

SUBSTANTIAL NATURAL GAS LEAK ON PG&E PIPELINE.

INCIDENT TYPE / DESCRIPTION:

Community Warning System Level (Circle Highest Level): N/A 0 1 2 3

FACILITY	ISO / MCAR	TRANSPORTATION	MISCELLANEOUS
<input type="checkbox"/> Fire or Explosion	<input type="checkbox"/> Fatality (one or more)	<input type="checkbox"/> Tank Truck	<input type="checkbox"/> Storm Drain/Creek
<input type="checkbox"/> Spill or Release	<input type="checkbox"/> > 24 hrs. Hospital, 3 or more people	<input type="checkbox"/> Railroad	<input type="checkbox"/> Drug Lab
<input type="checkbox"/> Startup or Shutdown	<input type="checkbox"/> Flammable Vapor Cloud > 5,000 lbs.	<input type="checkbox"/> On Water	<input type="checkbox"/> Disposal/Abandonment
<input type="checkbox"/> Flaring		<input checked="" type="checkbox"/> Pipeline	<input checked="" type="checkbox"/> Odor Complaint
<input type="checkbox"/> Upset		<input type="checkbox"/> Fuel Tank	<input type="checkbox"/> Other:

Time Enroute to Scene: 12:30PM Time Arrived On Scene: 12:51PM Time Departed From Scene: 14:22

REFERRED TO OTHER AGENCY:



DTSC STATE FUNDING (if applicable): CLU/ERER Number:	STORMWATER STATUS (if applicable): <input type="checkbox"/> Actual Discharge <input type="checkbox"/> Potential Discharge
--	---

AGENCIES ON SCENE OR NOTIFIED:

Agency Type	Agency	O/N	Contact Person	Phone Number	Case Number
Fire Department	EL CERRITO FIRE DEPARTMENT	O	BC JOSE CASTREJON	510-215-4450	
Law Enforcement	CITY OF PINOLE POLICE DEPARTMENT	O	CAPT WILL PALMINI	510-724-8950	P19-1178
Air District					
State OES		N			19-3409
	PG&E	O	DANITA SEATON	510-227-7153	

REPORT:

At 12:17PM, Contra Costa County Fire Protection District (CONFIRE) requested Contra Costa Health Services Hazardous Materials Programs (CCHSHMP) to respond to a substantial natural gas leak from a PG&E pipeline near 759 Pine Avenue, Pinole.

At 12:30PM, HM1 (JP&MPD) departed the office.

At approximately 12:40PM, HM2 (XB&DWL) departed the office.

At 12:51PM, HM1 arrived on scene.

At 13:01, IW arrived on scene in a personal vehicle.

At 13:04, HM2 arrived on scene.

CCHSHMP assisted El Cerrito Fire Department with air monitoring. People living in 10 houses on Smith Avenue and Pine Avenue were evacuated. People on Appian Way and Marlesta Rd were ordered to shelter in place. A natural gas odor was observed at Smith Ave and San Pablo Ave. CGI detected 2 ppm reading at Smith Ave and San Pablo Ave. King Kong Plumbing Services representative stated that they dug the hole in front of residential property located at 759 Pine Avenue for sewage pipe repair. King Kong Plumbing Services representative stated that they contacted 811 weeks before the digging. King Kong Plumbing Services representative stated that the wrong location for PG&E pipeline was marked.

At 13:14, no mercaptan odor and normal gas (O2, CO, %LEL, and H2S) readings on CGI and 4 gas meters were noted on Maiden Ln.

At 13:17, no mercaptan odor and normal gas readings on CGI and 4 gas meters were noted on Jones Ave between San Pablo Ave and Jones Ct.

At 13:18, slight mercaptan odor observed during gusts of wind on Maiden Ln curve.

At 13:22, no mercaptan odor and normal gas readings on CGI and 4 gas meters were noted between Smith Ave and Appian Way.

Big Minds located at 1937 San Pablo Ave, St. Joseph's School on 1961 Plum Street, Pinole Middle School located at 1575 Mann Drive, and Collin's Elementary on 1224 Pinole Valley Road were notified.

At 13:25, no mercaptan odor and normal gas readings on CGI and 4 gas meters were noted on Marlesta Rd.

At 13:30, no mercaptan odor and normal gas readings on CGI and 4 gas meters were noted between Appian Way and Jones Ave and on San Pablo Ave.

At approximately 13:30, El Cerrito Fire Department lifted shelter in place from 789 to end of Pine Ave and 710 to end of Smith Ave.

At 13:43, no mercaptan odor and normal gas readings on CGI and 4 gas meters were noted between Marlesta Rd and San Pablo Ave. Strong mercaptan odor and no readings were noted at San Pablo Ave and Smith Ave.

At 13:46, 4% LEL was noted at the source.

At 13:47, mercaptan odors and normal gas readings on CGI and 4 gas meters were noted between San Pablo Ave and the terminus of Maiden Ln.

At 13:50, PG&E applied a pipe clamp to cutoff the gas feed to the damaged pipe approximately 2 houses away and stopped the leak.

At 13:54, normal gas readings on CGI and 4 gas meters were noted at the source. PG&E was working to repair the pipeline. The evacuation was lifted on Pine Ave. Incident Command (IC) determined all clear.

At 13:59, CCHSHMP notified CAL OES about the release.

At 14:05 HM2 and IW departed the scene.

At 14:13, no mercaptan odor and normal gas readings on CGI and 4 gas meters were noted at Collin's Elementary on 1224 Pinole Valley Rd.

At 14:22, HM1 departed the scene.

At 14:28, no mercaptan odor and normal gas readings on CGI were noted at St. Joseph's School on 1961 Plum Street.

Additional Required Items: Bill of Lading, Request for Invoice, and Site Safety Plan

Report Prepared by: JP

[EXTERNAL] Hazardous Materials Spill Report: Cal OES Control #:19-3409

Warning Center <Warning.Center@oes.ca.gov>

Tue 2019-05-28 2:14 PM

To:ccchazmat@hsd.cccounty.us <ccchazmat@hsd.cccounty.us>;

Governor's Office of Emergency Services
Hazardous Materials Spill Report

DATE: 05/28/2019 | RECEIVED BY Cal OES: Justin Christiansen | Cal OES CNTRL #:19-3409

TIME: 1359 | RECEIVED BY OSPR: | NRC#:

1.a. PERSON NOTIFYING Cal OES

1. NAME: John Pham | 2. AGENCY: Contra Costa County Hazmat
3. PHONE #: 916-335-3200 | 4. EXT: | 5. PAGER #:

1.b. PERSON REPORTING SPILL (If different from above):

1. NAME: | 2. AGENCY:
3. PHONE #: | 4. EXT: | 5. PAGER #:

2. SUBSTANCE TYPE:

a. SUBSTANCE: / b.QTY: / Amount / Measure / c. TYPE / d. OTHER / e. PIPELINE / f. Vessel Over => 300 tons

1. Natural Gas / = / Unknown / N/A / VAPOR / / No / No

2.

3.

g. DESCRIPTION: RP states: A plumber was excavating and broke a 1/2 inch line resulting in the release and 10 houses being evacuated. The release was stopped 1350 hours and evacuations were lifted shortly after. Repairs are in progress now through PGE. Smith Avenue and Marlesta Road were ordered to shelter in place and the shelter in place order was lifted

at 1332 hours. At the time of the leak there was a 4% LeI.
h. CONTAINED: Stopped | i. WATER INVOLVED: No
j. WATERWAY: | k. DRINKING WATER IMPACTED: No
l. KNOWN IMPACT: None

3.a. INCIDENT LOCATION: 759 Pine Avenue
b. CITY: Pinole | c. COUNTY: Contra Costa County | d. ZIP:

4. INCIDENT DESCRIPTION:
a. DATE: 5/28/2019 | b. TIME(Military): 1153 | c. SITE: Residence
| d. CAUSE: Human Error
e. INJURIES: No | f. FATALITY: No | g. EVACUATIONS: Yes | h.
CLEANUP BY: PGE
e. INJURIES #: | f. FATALS #: | g. EVACS #: 10 household were
evacuated.

5. SUSPECTED RESPONSIBLE PARTY:
a. NAME: | b. AGENCY: King Kong Plumbing Services
c. PHONE#: 510-759-9813 | d. EXT:
e. MAIL ADDRESS: Unknown
f. CITY: | g. STATE: CA | h. ZIP:

6. NOTIFICATION INFORMATION:
a. ON SCENE: Fire Dept., Police Dept. | b. OTHER ON SCENE: PGE, Co
Co Hazmat
c. OTHER NOTIFIED:
d. ADMIN. AGENCY: Contra Costa County Health Services Department
e. SEC. AGENCY:
f. ADDITIONAL COUNTY: g. ADMIN. AGENCY:
h. NOTIFICATION LIST: DOG Unit: | RWQCB Unit: 2

AA/CUPA, DTSC, RWQCB, US EPA, USFWS, AIR RESOURCES BD, EMSA, Co/WP,
Co/Hlth, Co/E-Hlth

CONFIDENTIAL REMARKS:

Created by Warning Center on 5/28/2019 1:59:49 PM Last
Modified by Warning Center on 5/28/2019 2:14:32 PM

California State Warning Center
Governor's Office Emergency Services
Phone: (916) 845-8911
Warning.Center@oes.ca.gov

Link to Spill Report:

https://urldefense.proofpoint.com/v2/url?u=http-3A_w3.calema.ca.gov_operational_malhaz.nsf_SpillAllDocs_1016C66BA696E3258825840800735727-3FOpenDocument&d=DwlBAg&c=RpR9LiQNIoGO8A8CMgA1NQ&r=S0jS0A081QNgB4a-k_X9SD1TTubB3usfrG7WkczC2Lg&m=du4toqQnS2ZzkGp3beUSegnLCL_wDgTtg5gSwwPDSXM&s=XtCmVhC34DscgnwAXo3sibRUJskRoJeVMH4bZdKxAjM&e=