



**COMPLAINT, INCIDENT, AND NOTIFICATION REPORT FORM**

Type (Circle One):  C  I  N

Received Date: 10/17/18 Received Time: 22:32 Received By: AA Lead: AA  
 Incident Date: 10/17/18 Incident Time: 20:30 Assigned to: \_\_\_\_\_ Assigned Date: \_\_\_\_\_

**CASE NUMBER:** 181017 -03

**COMPLAINANT / REPORTING PARTY:**

Name: Con Fire Dispatch  RP is from Facility  Anonymous  
 Organization: \_\_\_\_\_ Cal OES # (if applicable) 18-7055  
 Primary Phone Number: 925-933-1313 Secondary Phone Number: \_\_\_\_\_  
 Email: \_\_\_\_\_  
 Address: \_\_\_\_\_  
 City: \_\_\_\_\_ State: \_\_\_\_\_ Zip Code: \_\_\_\_\_

**FACILITY / LOCATION OF INCIDENT:**

Name: \_\_\_\_\_ CUPA Facility I.D.: \_\_\_\_\_  
 Phone Number: \_\_\_\_\_  
 Address: Lat 38.0314324, Long -121.9347627 Unit: \_\_\_\_\_  
 City: Bay Point State: CA Zip Code: 94565  
 Location Description: Unnamed street at corner of Poinsettia and Suisun Ave.

**INITIAL INCIDENT DESCRIPTION:**

Fire in a vault at a natural gas line release.

**INCIDENT TYPE / DESCRIPTION:**

Community Warning System Level (Circle Highest Level):  N/A  0  1  2  3

FACILITY	ISO / MCAR	TRANSPORTATION	MISCELLANEOUS
<input checked="" type="checkbox"/> Fire or Explosion <input checked="" type="checkbox"/> Spill or Release <input type="checkbox"/> Startup or Shutdown <input type="checkbox"/> Flaring <input type="checkbox"/> Upset	<input type="checkbox"/> Fatality (one or more) <input type="checkbox"/> > 24 hrs. Hospital, 3 or more people <input type="checkbox"/> Flammable Vapor Cloud > 5,000 lbs.	<input type="checkbox"/> Tank Truck <input type="checkbox"/> Railroad <input type="checkbox"/> On Water <input checked="" type="checkbox"/> Pipeline <input type="checkbox"/> Fuel Tank	<input type="checkbox"/> Storm Drain/Creek <input type="checkbox"/> Drug Lab <input type="checkbox"/> Disposal/Abandonment <input type="checkbox"/> Odor Complaint <input type="checkbox"/> Other:

Time Enroute to Scene: 11:22pm Time Arrived On Scene: 11:46pm Time Departed From Scene: 2:05pm

**REFERRED TO OTHER AGENCY:**



<b>DTSC STATE FUNDING (if applicable):</b> CLU/ERER Number:	<b>STORMWATER STATUS (if applicable):</b> <input type="checkbox"/> Actual Discharge <input type="checkbox"/> Potential Discharge
--	---

**AGENCIES ON SCENE OR NOTIFIED:**

<b><u>Agency Type</u></b>	<b><u>Agency</u></b>	<b><u>O/N</u></b>	<b><u>Contact Person</u></b>	<b><u>Phone Number</u></b>	<b><u>Case Number</u></b>
Fire Department	Contra Costa Fire	O	Jim Huntze	925-383-5037	
Law Enforcement	Pittsburg Police Department	O			
Air District					
State OES		N			18-7055

**REPORT:**

See Branch Operations Center Log for Timeline of Events

**Additional Required Items: Bill of Lading, Request for Invoice, and Site Safety Plan**

**Report Prepared by:** \_\_\_\_\_



**{In Archive} [EXTERNAL] Hazardous Materials Spill Update: Cal OES Control #18-7055**

Warning Center to: amanda.ackerman

10/24/2018 11:17 AM

Archive:

This message is being viewed in an archive.

Governor's Office of Emergency Services  
Hazardous Materials Spill Update

CONTROL #: 18-7055 NRC#: 1227968 / 1228218 / 1228397

NOTIFY DATE/TIME: 10/17/2018 / 2142  
RECEIVED BY: Blake Tyson | OCCURENCE DATE/TIME:10/17/2018 / 2030  
CITY/OP. AREA: Bay Point/Contra Costa County

1.a. PERSON NOTIFYING Cal OES  
PERSON CALLING Cal OES: Makenzie Miller | AGENCY: Chevron  
PHONE #: 337-513-2562 | EXT: | PAGER #(CELLPHONE):

1.b. PERSON REPORTING SPILL (If different from above):  
PERSON CALLING Cal OES: | AGENCY:  
PHONE #: | EXT: | PAGER #(CELLPHONE):

SUBSTANCE TYPE:  
a. SUBSTANCE: / b.QTY: Amount / Measure / c. TYPE / d. OTHER / e.  
Pipeline / f. Vessel Over => 300 tons  
1. Fuel - Butane, Medium BTU / Unk / Lbs. / VAPOR / / Yes / No  
-----  
2.  
-----  
3.  
-----  
4.

Original Description: Powerline dropped on a sub surface vault and made contact with a transmitter causing the release, material is combusting and flowed directly into the atmosphere, line is isolated and shut in but residual in the line is still burning, FD is handling the containment, RP is performing clean up.

Update(s): 10/17/2018 10:10:19 PM - " CALLER REPORTED THAT A POWERLINE FELL AND A GAS PIPELINE CAUGHT ON FIRE AND ITS IS RELEASING MATERIAL TO THE ATMOSPHERE. NO INJURIES REPORTED. THE FD IS ON-SCENE.  
; 10/17/2018 11:13:27 PM - RP reports that fire is still burning and approximately 1,000 - 1,500 people are being evacuated from the surrounding area.  
; 10/19/2018 01:57:28 PM - Per the caller the confirmed release amount associated with the fire is 71 MCF. Per the caller the controlled release of the blow down is 1.4MCF. All damage from the incident is being reviewed and repaired,  
; 10/19/2018 02:13:38 PM - Received NRC# 1227968: \*\*\*THIS IS A 48 HOUR

UPDATE UNDER PHMSA REGULATIONS TO NRC 1227786\*\*\* THE UPDATE IS AS FOLLOWS:  
TOTAL MATERIAL RELEASED IS 8.5 MCF. MATERIAL RELEASED IS MEDIUM BTU NATURAL  
GAS. DAMAGES ARE BEING ASSESSED AND REPAIRED. CALLER REPORTED THAT A  
POWERLINE FELL AND A GAS PIPELINE CAUGHT ON FIRE AND ITS IS RELEASING  
MATERIAL TO THE ATMOSPHERE. NO INJURIES REPORTED. THE FD IS ON-SCENE.  
CHEVRON IS RESPONDING, FD IS ON-SCENE.

; 10/22/2018 03:34:37 PM - Called to update amount: A total of 7,100 cubic  
feet of Natural Gas released during the incident. NRC report also received,  
no additional information.

; 10/24/2018 10:40:51 AM - Per the caller the initial release associated  
with the fire was 7,100 cuft, the controlled release to blow down the line  
is estimated at 1,410,000 cuft. The total release volume 1,417,150 cuft

; 10/24/2018 11:15:09 AM - PER THE NRC REPORT \*\*\*UPDATE TO PREVIOUS PHMSA  
UPDATE (1228218)

CALLER UPDATING THE THE TOTAL VOLUME OF MATERIAL RELEASED (COMBINING  
AMOUNT RELEASED FROM FIRE AND CONTROLLED RELEASE TO BLOW DOWN).  
THE TOTAL VOLUME 1,417,100 CUBIC FEET (1.42 MMCF). PIPELINE IS  
BELOW GROUND BUT RELEASE OCCURRED IN A VAULT. AMOUNT INVOLVED IN  
FIRE RELEASED WAS (7100 CBF AND AMOUNT INVOLVED IN CONTROLLED BLOW  
DOWN WAS (1,410,000 CBF)

\*PHMSA 48-HOUR UPDATE FOR REPORT 1227968\*

CALLER IS REPORTING AN UPDATE TO THE AMOUNT RELEASED TO 7.1 MCF OF  
NATURAL GAS.

ORIGINAL REPORT:

\*\*\*THIS IS A 48 HOUR UPDATE UNDER PHMSA REGULATIONS TO NRC  
1227786\*\*\* THE UPDATE IS AS FOLLOWS: TOTAL MATERIAL RELEASED IS 8.5  
MCF. MATERIAL RELEASED IS MEDIUM BTU NATURAL GAS. DAMAGES ARE  
BEING ASSESSED AND REPAIRED.

CALLER REPORTED THAT A POWERLINE FELL AND A GAS PIPELINE CAUGHT ON  
FIRE AND ITS IS RELEASING MATERIAL TO THE ATMOSPHERE. NO INJURIES  
REPORTED. THE FD IS ON-SCENE.

-----  
PERSON NOTIFYING Cal OES OF SPILL UPDATE:

NAME: XXX | AGENCY: NRC

PHONE #: 800-424-8802 | EXT: | PAGER #(CELLPHONE):

-----  
UPDATE QUANTITY:

1. Amount: Lbs.
2. Amount:
3. Amount:
4. Amount:

-----  
UPDATE RECEIVED BY: Devin Clarke

UPDATE KNOWN IMPACT:

UPDATE CAUSE:

SITUATION UPDATE: PER THE NRC REPORT \*\*\*UPDATE TO PREVIOUS PHMSA UPDATE  
(1228218)

CALLER UPDATING THE THE TOTAL VOLUME OF MATERIAL RELEASED (COMBINING  
AMOUNT RELEASED FROM FIRE AND CONTROLLED RELEASE TO BLOW DOWN).  
THE TOTAL VOLUME 1,417,100 CUBIC FEET (1.42 MMCF). PIPELINE IS  
BELOW GROUND BUT RELEASE OCCURRED IN A VAULT. AMOUNT INVOLVED IN  
FIRE RELEASED WAS (7100 CBF AND AMOUNT INVOLVED IN CONTROLLED BLOW  
DOWN WAS (1,410,000 CBF)

\*PHMSA 48-HOUR UPDATE FOR REPORT 1227968\*  
CALLER IS REPORTING AN UPDATE TO THE AMOUNT RELEASED TO 7.1 MCF OF  
NATURAL GAS.

ORIGINAL REPORT:

\*\*\*THIS IS A 48 HOUR UPDATE UNDER PHMSA REGULATIONS TO NRC  
1227786\*\*\* THE UPDATE IS AS FOLLOWS: TOTAL MATERIAL RELEASED IS 8.5  
MCF. MATERIAL RELEASED IS MEDIUM BTU NATURAL GAS. DAMAGES ARE  
BEING ASSESSED AND REPAIRED.

CALLER REPORTED THAT A POWERLINE FELL AND A GAS PIPELINE CAUGHT ON  
FIRE AND ITS IS RELEASING MATERIAL TO THE ATMOSPHERE. NO INJURIES  
REPORTED. THE FD IS ON-SCENE.

---

CONFIDENTIAL:

---

FAX NOTIFICATION LIST: AA/CUPA, DTSC, RWQCB, US EPA, USEWS, AIR  
RESOURCES BD, CDPH-D.O., PUC, SFM, Co/WP, Co/Hlth, Co/E-Hlth  
ADMINISTERING AGENCY: Contra Costa County Health Services Department  
SECONDARY AGENCY:  
OTHER NOTIFIED:

Created by Warning Center on 10/24/2018 11:15:09 AM  
Modified by Warning Center on 10/24/2018 11:17:13 AM

Last

California State Warning Center  
Governor's Office of Emergency Services  
Phone: (916) 845-8911  
Warning.Center@oes.ca.gov